



WIRING KEY
 - - - - - FIELD
 _____ FACTORY
 - - - - - PANEL BOX/DOOR

NOTES:
 REMOVE BLACK WIRE TO TERMINAL TB2-1 FOR:
 *CT-6/10 W/ POWERFLAME GAS BURNER
 *CT-15 W/ POWERFLAME GAS W/ BURNERS
 USING S8680J CONTROL
 *CT-6/10/15/20 W/ BECKETT OIL ONLY WHEN
 USING R7184B

COLUMBIA BOILER
 CT-6/25, WITH MDP,
 PANEL BOX WIRING W/ CONTACTOR, DANFOSS

DATE: 06/15/11	DRAWING: WD-1805
DRAWN BY: JPW	REVISION: